



CITY OF SCOTTVILLE 2019 ANNUAL WATER QUALITY REPORT

We are pleased to present this year's Annual Water Quality Report to our valued customers. This report, as required by the United States Environmental Protection Agency (EPA) under the Safe Drinking Water Act re-authorization, is designed to inform the consumer about where your water comes from, what it contains, and how it compares to standards set forth by regulatory agencies. Our constant goal is to provide our customers with a safe and dependable drinking water supply. We continually strive to improve the water treatment process and distribution system. We appreciate the confidence our customers have placed in us and continually value your trust.

WHERE DOES YOUR WATER COME FROM?

The water used by the residents of the City of Scottville is purchased from the City of Ludington. Their water is drawn through two intake structures in Lake Michigan primarily through a submerged intake that is connected to the water treatment plant by a 36-inch diameter pipe. A crib-style intake, attached to a 24-inch diameter pipe, is also used to supplement the buried intake capacity and functions as a backup. The City of Ludington operates an 8.0 million gallon per day capacity conventional treatment facility which is staffed by a team of 8 licensed operators. This facility uses coagulation, flocculation, sedimentation, and filtration treatment processes to provide high quality aesthetically pleasing drinking water for the community. In addition, fluoride is also added to the water at the treatment plant for the prevention of tooth decay.

DRINKING WATER QUALITY RESULTS

The City of Scottville's licensed water treatment operators routinely monitor for contaminants in your drinking water according to Federal and State laws. Results are gathered through a certified lab, as well as other independent laboratories including the State of Michigan Department of Environmental Quality (MDEQ) lab. It is important to mention that not all contaminants are tested for every year because the concentrations of these contaminants are not expected to vary significantly from year to year as determined by our State regulatory agency the (MDEQ). **We are proud of the fact that your drinking water meets or surpassed all Federal and State water quality and safety standards for 2019.** However, should there ever be an immediate health threat due to a water contaminant problem or violation we would promptly notify you by the best means possible. We perform numerous tests each day to monitor our source water, various water treatment stages and of course, the tap. The table inside this report represents the substances that were detected in Scottville's water for the monitoring period of January 1st to December 31st, 2019.

HEALTH AND SAFETY INFORMATION

Drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily pose a health risk. The sources of both tap and bottled drinking water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials, and can also pick up substances resulting from animal or human activity.

Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants, such as salts and metals, which can be naturally occurring, or result from urban storm water runoff and residential uses; Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, septic

systems, and urban or agricultural runoff (i.e., pesticides and herbicides); or Radioactive contaminants, which can be naturally occurring or the result of oil and gas production and mining activities.

To ensure that tap water is safe, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Information for Vulnerable Populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. More information on potential effects of specific contaminants can be obtained by contacting the EPA's Safe Drinking Water Hotline at 800.426.4791 or their website at <http://www.epa.gov/safewater/dwhealth.html>.

Lead and Drinking Water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Scottville is responsible for providing high quality drinking water, but cannot control the variety of materials in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two (2) minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at <http://epa.gov/safewater/lead>.

PFAS: Per and polyfluoroalkyl substances (PFAS) are a group of man-made chemicals that include PFOA, PFOS, GenX, and many other chemicals. PFAS compounds have been manufactured and used in a variety of industries in the United States since the 1940s. The State of Michigan Department of Environment, Great Lakes, and Energy (EGLE) in collaboration with their partners monitored all 1,114-community water supplies during the Statewide Testing Initiative in 2018 and 2019. The State of Michigan EGLE has drafted regulations to add maximum contaminant levels (MCL) for 7 specific PFAS compounds. Results from the Statewide Testing Initiative show non-detect levels of PFAS compounds in the City of Ludington's drinking water.

SPECIAL INFORMATION

The Michigan Department of Environmental Quality (MDEQ) has completed a Source Water Assessment for the City of Ludington's Water Supply in 2003. This report is intended to encourage protection of water sources, provide information for water shed assessment and planning, direct additional water studies and improve land use planning. For more information concerning the Source Water Assessment contact the Ludington Water Treatment Plant at 231.843.8830.

City staff is available 24-hrs. a day to provide quality water to its residents and customers. If you have any questions or comments, or would like to receive more specific information about Scottville's Water System, please feel free to call Marc Hansen, at 231-690-0298 or the City Hall at 231-757-4729 from 8:00 am to 4:00 pm Monday thru Friday.

Interested citizens are welcome to attend City Commission meetings to hear more about current projects involving Scottville's water system. Meetings are held on the first and third Mondays of each month at 5:30 p.m. at the Scottville City Hall, 105 North Main Street, Scottville, MI 49454.

This report is also available at the Scottville City Hall, Scottville Library and the Scottville Post Office as well as the city website at www.cityofscottville.org.

2019 WATER QUALITY RESULTS TABLE

Regulated Monitoring at the Treatment Plant								
Substance	Units	Range Detected	Level Detected	MCL	MCLG	Violations	Year Sampled	Possible Sources of Contaminant
Barium	ppm	0.02	0.02	2	2	No	2019	Erosion of natural deposits
Fluoride	ppm	0.65 - 0.78	0.72	4	4	No	2019	Water additive which promotes strong teeth
Turbidity ^[1]	ntu	0.03 - 0.12	0.04	TT=1	NA	No	2019	Soil runoff, suspended matter in lake water
Total Organic Carbon ^[2]	ppm	1.30 - 1.90	1.66	TT	NA	No	2019	Naturally present in the environment
Nitrate	ppm	ND	ND	10	10	No	2019	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Gross Alpha	pCi/L	1.93	1.93	15	0	No	2018	Erosion of natural deposits
Combined Radium 226/228	pCi/L	0.74	0.74	5	0	No	2018	Erosion of natural deposits
Total Xylenes	ppm	ND	ND	10	10	No	2019	Leaks and spills from gasoline and petroleum storage tanks
Regulated Monitoring in the Distribution System								
Substance	Units	Range Detected	Level Detected	MCL	MCLG	Violations	Year Sampled	Possible Sources of Contaminant
Haloacetic Acids ^[3]	ppb	8.0 - 22.0	15.75	60	0	No	2019	Formed when chlorine is added to water with naturally occurring organic material
Total Trihalomethane ^[3]	ppb	35.4 - 64.5	50.65	80	0	No	2019	
Free Chlorine Residual ^[4]	ppm	0.28 - 1.06	0.63	MRDL=4	MRDLG=4	No	2019	Used to disinfect drinking water
Regulated Monitoring at Customer's Tap								
Substance	Units	Range Detected	Action Level (AL)	90th Percentile	MCLG	Number of Samples	Year Sampled	Possible Sources of Contaminant
Lead	ppb	ND	15.0	0	0	0	2017	Corrosion of household plumbing system
Copper	ppm	0.02-0.04	1.3	0.037	1.3	0	2017	Corrosion of household plumbing system
Unregulated Monitoring								
Substance	Units	Range Detected	Level Detected	MCL	MCLG	Violations	Year Sampled	Possible Sources of Contaminant
Sodium	ppm	9.0	9.0	NA	NA	No	2019	Erosion of natural deposits
PFAS	ppt	ND	ND	NA	NA	No	2019	Fire suppression foam; household products
Footnotes:								
1. Turbidity is a measurement of water clarity. We monitor turbidity because it is a good indicator of our filtration process. The turbidity measurements must be less than or equal to 0.3 ntu in 95% of all samples taken each month and shall never exceed 1 ntu at any time.								
2. The level detected shown for Total Organic Carbon (TOC) is the running annual average calculated quarterly.								
3. The level detected shown for Total Trihalomethanes (TTHM) and Haloacetic Acids (HAA5) is the running annual average calculated quarterly.								
4. The level detected shown for Free Chlorine Residual was calculated using a running annual average.								
Terminology:								
Parts per million (ppm) and parts per billion (ppb) - One ppm can be equated to a single penny in \$10,000. One ppb is a single penny in \$100,000,000.								
Picocuries per Liter (pCi/L) - A measure of radioactivity.								
Maximum Contaminant Level (MCL) - The MCL is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible, using the best available treatment technology. MCL's are set at very stringent levels by the State and Federal government. To understand the possible health effects, a person would have to drink about two liters (quarts) of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the associated health effect.								
Maximum Contaminant Level Goal (MCLG) - The MCLG is the level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs provide a margin of safety.								
Maximum Residual Disinfection Level (MRDL) - The highest level of disinfectant allowed in drinking water. There is convincing evidence that the addition of a disinfectant is necessary for control of microbial contaminants.								
Maximum Residual Disinfection Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.								
follow.								
Nephelometric Turbidity Unit (ntu) - Measurement of water clarity.								
Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.								
(NA) - Not Applicable								
(ND) - Not Detected at testing limits.								